



CHEMICAL COMPANY REDUCES UNCERTAINTY IN CRITICAL ETHYLENE FLOW MEASUREMENT

Customer

Chemical company in Texas, USA

Application

Custody transfer of ethylene

Challenge

A chemical company in Texas needed to improve their flow measurement on a 6 inch (150 mm) ethylene line. Ethylene is a valuable feedstock, representing a sizeable investment. The annual throughput on the line was approximately 442,000,000 lb/yr (200,000,000 kg/yr) with a financial value of \$250,000,000. It was critical that the flow measurement be as accurate as possible because even a small error could have a large financial impact.

Mass flow measurement was accomplished through pressure and temperature compensation of an orifice meter. A Rosemount™ 3144P temperature transmitter and a standard class B thin film RTD provided the temperature compensation for this meter. The sensor interchangeability error for this RTD is about 0.7° F (0.4° C) at the flowing temperature of 68° F (20° C). Under normal flow conditions (100 inches H₂O (248 mbar) DP and 500 psig (34.5 bar)), the flow rate was 50,493 lb/hr (22,900 kg/hr). Because the indicated temperature could be up to 0.7° F (0.4° C) in error, the flow measurement would be impacted by as much as 2%. This would translate into \$4,790,000 of measurement error per year.

Results

- Temperature uncertainty reduced from $\pm 0.7^\circ$ F to 0.25° F
- Flow measurement uncertainty reduced by 65%
- Immediate payback on instrument investment



Image 1. Gas flow rate uncertainty can be drastically improved when temperature error is reduced.

CHEMICAL COMPANY REDUCES UNCERTAINTY IN CRITICAL ETHYLENE FLOW MEASUREMENT

Solution

In order to improve the temperature measurement in this flow application, the company decided to take advantage of the transmitter-sensor matching capability of the Rosemount 3144P. The existing RTD was replaced with a Rosemount Series 68 (now called the Rosemount 214C Series) RTD that included Callendar-Van Dusen constants specific to that sensor. By simply programming the four provided constants into the Rosemount 3144P, the temperature measurement error was reduced by a factor of three - to an uncertainty of $\pm 0.25^\circ\text{F}$ ($\pm 0.15^\circ\text{C}$).

This simple change reduced the flow uncertainty due to temperature uncertainty from 2% to 0.675%. The financial implication of this measurement improvement totalled \$3,100,000 over a one year period. Payback on the instrumentation investment was almost instantaneous.

“

By simply programming the four provided constants into the Rosemount 3144P, the temperature measurement error was improved by a factor of three.

”

Resources

Emerson's Chemical Industry Solutions
[Emerson.com/Chemical](https://www.emerson.com/Chemical)

Rosemount 3144P Temperature Transmitter
[Emerson.com/TemperatureTransmitters](https://www.emerson.com/TemperatureTransmitters)

For more information, visit
[Emerson.com/TemperatureMeasurement](https://www.emerson.com/TemperatureMeasurement)

The Emerson logo is a trademark and service mark of Emerson Electric Co.
Brand logotype are registered trademarks of one of the Emerson family of companies.
All other marks are the property of their respective owners.
©2023 Emerson Electric Co. All rights reserved.

00830-0100-4021 Rev EB