



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 14ATEX2122X** Issue: **10**

4 Equipment: **TX* Series Valve Position Indicators**

5 Applicant: **TopWorx Inc.**

6 Address: **3300 Fern Valley Road
Louisville
Kentucky 40213
USA**

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0:2018 EN 60079-11:2012 IEC 60079-31:2014

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:



II 2GD^①

Ex ia IIC T^② Gb (Ta = -^②°C to +^②°C)

Ex tb IIIC T^②°C Db (Ta = -^②°C to +^②°C)

IP66/67

① II 2G for products bearing a T3 temperature class.

② The temperature class, ambient temperature range and surface temperature depend on devices used in the construction of these products, see Conditions of Manufacture.



Signed: M Halliwell
Title: Director of Operations

Project Number 80188648

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2122X
Issue 10

13 DESCRIPTION OF EQUIPMENT

The Valve Position Indicators consist of a metal enclosure (approximately 150 mm x 100 mm by 60 mm) comprising a body and a lid. There is a plastic dome housing a visual indicator; the dome does not contribute to the ingress protection. There are threaded entries to allow the installation of cable glands.

Enclosures types

| Model | Body | Lid | Dome |
|-------|-----------------|-----------------|-------|
| TXP | Aluminium | Aluminium | Lexan |
| TXS | Stainless Steel | Stainless Steel | Lexan |

Internally, a rotating cam activates a number of internal devices that sense the status of the valve position. The approved internal devices are as shown in the Condition of Manufacture section of the certificate.

Variation 1 - This variation introduced the following changes:

- i. The following reductions in the lower ambient temperature were approved for devices intended for use in flammable gas atmospheres:
 - -65°C for Valve Position Indicators containing only simple switches
 - -60°C for PTB-certified P+F switches to; for group IIC gas certification only
- ii. The introduction of a T3 temperature class option; this applies to Valve Position Indicators containing only simple switches that are intended for use in flammable gas atmospheres.
- iii. An existing Condition of Manufacture was reviewed and revised to recognise new values and to clarify the content.
- iv. The addition of line fault detection options for devices intended for use in flammable gas atmospheres with T4 and T3 temperature classes; as a result, a new condition of manufacture was added.
- v. The address of the manufacturing location in China was changed from Fisher Controls Division, Bao Heng Technology Industry Park, North Hong Lang 2nd Road, District 68 Bao'an District, Shenzhen 518101 to Fisher Controls Division, Bao Heng Technology Industry Park, Liu Xian 1st Road, District 68, Bao'an District, Shenzhen 518101.
- vi. The address of the manufacturing location in Hungary was changed from H-8001 Szekesfehervar Berenyi U, 72-100 to Holland Faszor 6, Szekesfehervár.

Variation 2 - This variation introduced the following change:

- i. To include the component-certified Series 36 Go Switch (option Q) as an alternative option for the Series 35 Go Switch, with resulting amendments to the Conditions of Manufacture.

Variation 3 - The introduction of the change of manufacturing location:

| | |
|-------------------------|-------------------------|
| From: | To: |
| Emerson Process Mgmt | ASCO Numatics Sp.z o.o. |
| Magyarország | Kurczaki 132 |
| Holland Faszor 6 | 93 331 Lodz |
| Szekesfehervar, Hungary | Poland |
| 8000 | |

Project Number 80188648

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2122X
Issue 10

Variation 4 - This variation introduced the following changes:

- i. The introduction of the Series 36SD GO Switch, associated with new sensing options D2, D4.
- ii. Condition of Manufacturer referencing "Internal Components Table" was revised to include D sensing options to ID 17 LED Board and add ID 17 to include the new Go Switch.
- iii. Condition of Manufacturer referencing "The temperature class, ambient temperature range and surface temperature" was revised to add ID 17; to include the temperature class, ambient temperature range and surface temperature information for the new Go Switch.

Variation 5 - This variation introduced the following change:

- i. The change to the name of the facility in Poland was recognised.
From: ASCO Numatics Sp. z o.o. To: Emerson Automation Fluid Control & Pneumatics Poland Sp. z o.o.

Variation 6 - This variation introduced the following changes:

- i. Add new ambient ranges for Pepperl +Fuchs Switches and sensors (Internal component ID 18) when used without any other components.
- ii. Add T5 temperature code for Simple Switches (Internal Component ID 1 to 6).
- iii. The Specific Conditions of Use and Conditions of Manufacture were amended.

Variation 7 - This variation introduced the following changes:

- i. Upgrade standard from EN 60079-0:2012/A11:2013 to EN IEC 60079-0:2018.
- ii. Update standard from IEC 60079-31:2013 to EN 60079-31:2014.
- iii. Update Ex component list and evaluate ASCO part "3021....IA" to EN IEC 60079-0:2018.
- iv. Update routine dielectric testing requirement by including 1.2 times AC/DC test voltage options with duration of 1 sec.
- v. Remove reference to alternative factory addresses from the certificate.

Variation 8 - This variation introduced the following changes:

- i. Conditions of Manufacture is revised to replace the Novotechnic WAL305 potentiometer with a generic 10k potentiometer that has a 0.5 mm separation distance through a solid insulation.
- ii. Manufacturer's Name & Address for ATEX certification is revised to reflect the latest QAN.

Variation 9 - This variation introduced the following change:

- i. Inclusion of ES-04900-2 component as an approved internal device in the Condition of manufacture.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Reports and Certificate History

| Issue | Date | Report number | Comment |
|-------|------------------|---------------|---------------------------------------|
| 0 | 22 August 2014 | R70004819B | The release of the prime certificate. |
| 1 | 02 November 2015 | R70024654A | The introduction of Variation 1. |

Project Number 80188648

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2122X
Issue 10

| Issue | Date | Report number | Comment |
|-------|-------------------|---------------|---|
| 2 | 27 October 2016 | R70070892B | This Issue covers the following changes: <ul style="list-style-type: none">• EC Type-Examination Certificate in accordance with 94/9/EC updated to EU Type-Examination Certificate in accordance with Directive 2014/34/EU. <i>(In accordance with Article 41 of Directive 2014/34/EU, EC Type-Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC Type-Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.)</i>• The introduction of Variation 1 |
| 3 | 31 January 2019 | R70209081A | The introduction of variation |
| 4 | 19 March 2019 | R70212945A | The introduction of Variation 4. |
| 5 | 15 October 2019 | 1136 | Transfer of certificate Sira 14ATEX2122X from Sira Certification Service to CSA Group Netherlands B.V. |
| 6 | 30 July 2020 | R80050077A | The introduction of Variation 5. |
| 7 | 14 September 2020 | R80047581A | The introduction of Variation 6. |
| 8 | 26 September 2022 | R80103690A | The introduction of Variation 7. |
| 9 | 08 January 2024 | R80188970A | The introduction of Variation 8. |
| 10 | 05 April 2024 | R80188649A | The introduction of Variation 9. |

15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)

- 15.1 The 4-20 mA loop circuit and the various additional sub-assemblies (switches, sensors, valves, etc.) shall be treated as separate intrinsically safe circuits.
- 15.2 The entity parameters for simple switches that are not covered by a certificate are $U_i = 30 \text{ V}$, $I_i = 200 \text{ mA}$ and $P_i = 0.72 \text{ W/switch (T4)}$ or $P_i = 0.34 \text{ W/switch (T5/T6)}$. The entity parameters of certified devices fitted shall be obtained from the applicable certificate.
- 15.3 If the equipment is fitted with a HART v7 Module, it may be supplied with a bonding strap that could be used to connect the shield (screen) of the cable to ground when installed in a metallic enclosure. In this case, the user/installer shall take this into consideration and ensure that earthing arrangements of the final circuitry comply with the requirements of the relevant Code of Practice.

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

17 CONDITIONS OF MANUFACTURE

- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of CSA Group Netherlands B.V. certificates.
- 17.2 Holders of EU-Type Examination Certificates are required to comply with the conformity to type requirements defined in Article 13 of Directive 2014/34/EU.

Project Number 80188648

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2122X
Issue 10

17.3 The Valve Position Indicators shall only be fitted with devices that that are listed in the table below. Where applicable; these devices shall also conform to the certificates, supplements and amendments that are also listed therein. Because the exact composition of the Valve Position Indicator is variable, Topworx Inc. shall:

- Supply the installer/end user with a full set of appropriate certificates and instructions that are relevant to the contents of the enclosure
- Indicate which certificates apply to the contents of the enclosure.

Internal Components Table

| ID* | Device | Sensing option | Type | Description |
|-----|---|------------------------------------|---|--|
| 1 | Mechanical switch | K | V7 | Simple switch |
| 2 | Go switch | L | 35 Series | Simple switch |
| 3 | Micro/Limit switch | M | VS10N001C2 | Simple switch |
| 4 | Reed switch | P | HSR-V933 | Simple switch |
| 5 | Reed switch | R | LV-ELE145 | Simple switch |
| 6 | DPDT Micro switch | T | Cherry Burrell E19 or ITW DPDT-ZZ #26-804 | Simple switch |
| 7 | ASCO Electro-valve Module | 1 or 2 | 3021....IA | INERIS 03ATEX0249X issue 4 |
| 9 | Pepperl + Fuchs Slot Type Initiators | N | SJ... & SC... (supply types 1, 2 + 3) | PTB 99ATEX2219X issue 1 plus supplement 1 |
| 10 | Pepperl + Fuchs Cuboidal Inductive Proximity sensor | E | Type NJ2-V3-N... (supply types 1, 2 + 3) | PTB 00ATEX2032X issue 1 plus supplement 1 |
| 11 | Pepperl + Fuchs Cuboidal Inductive Proximity sensor | E | All other types (supply types 1, 2 + 3) | PTB 00ATEX2032X issue 1 plus supplement 1 |
| 12 | Pepperl + Fuchs cylindrical inductive sensors | N | Types NC... and NJ... (supply types 1, 2 + 3) | PTB 00ATEX2048X issue 1 plus supplements 1, 2, 3, 4 |
| 13 | Pepperl + Fuchs SN sensors | N | Types NJ... and SJ... (supply types 1, 2 + 3) | PTB 00ATEX2049X issue 1 plus supplements 1, 2 |
| 14 | TopWorx 4-20 mA transmitter module & associated potentiometer | X | N/A | Sira 12ATEX2192U issue 3 |
| 15 | Turk Two Wire Proximity Sensors | N | Type ...-...-Y1.-.../... | KEMA 02ATEX1090X issue 8 |
| 16 | Go switch | Q | 36 Series | Baseefa 15ATEX0137U |
| 17 | GO Switch | D | 36 SD Series (D2 or D4) | DEM 19ATEX2173U |
| 18 | Pepperl+Fuchs Switches/sensors | N, E, B, F, J, V, 3 and N_+N _ _ _ | SC, SJ, NC or NJ (Only one type of switch to be used as per drawing CERT-ES-08677-1 without any other components) | PTB 00ATEX2032X issue 1 PTB 00ATEX2048X issue 1 PTB 00ATEX2049X issue 1 PTB 99ATEX2219X issue 1 |
| 19 | HART v7 | G | ES-04900-2 | IECEX SIR 16.0107U Issue 2 Sira 16ATEX2342U Issue 4 CSAE 21UKEX2700U Issue 1 |

Project Number 80188648

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

**Sira 14ATEX2122X
Issue 10**

* This number was created by CSA Sira and is used as a cross-reference to enable the marking that is applicable to each permissible device to be specified.

17.4 The temperature class, ambient temperature range and surface temperature depend on the devices used in the construction of these Valve Position Indicators, the manufacturer shall therefore mark their products in accordance with the table below.

| ID (see table above) | Gas or dust | Ambient temperature range (°C) | Temperature class or T*°C |
|----------------------|-------------|--|---------------------------|
| 1, 2, 3, 4, 5 and 6 | Gas | -65 to +55 | T6 |
| | | -65 to +70 | T5 |
| | | -65 to +85 | T4 |
| | | -65 to +100 | T3 |
| | Dust | -50 to +55 | T75°C |
| | | -50 to +85 | T104°C |
| 7 | Gas | -40 to +56 | T4 |
| | Dust | -40 to +56 | T75°C |
| 9 | Gas | -60 to +47 | T4 |
| | Dust | -50 to +47 | T75°C |
| 10 | Gas | -60 to +56 | T4 |
| | Dust | -50 to +56 | T75°C |
| 11 | Gas | -60 to +35 | T4 |
| | Dust | -50 to +35 | T75°C |
| 14 | Gas | -40 to +52 | T4 |
| | Dust | -40 to +52 | T75°C |
| 15 | Gas | -25 to +42 | T4 |
| | Dust | -25 to +42 | T75°C |
| 16 | Gas | -55 to +55 | T6 |
| | | -55 to +85 | T4 |
| | | -55 to +100 | T3 |
| | Dust | -50 to +55 | T75°C |
| | | -50 to +85 | T104°C |
| | | | |
| 17 | Gas | -55 to +55 | T6 |
| | | -55 to +85 | T4 |
| | Dust | -50 to +55 | T75°C |
| | | -50 to +85 | T104°C |
| | | | |
| | | | |
| 18 | Gas | Tamb and Tcode will depend on number of switches inside, as marked on internal labels (reference drawing CERT-ES08677-1) | |
| | Dust | -50 to +85 | T104°C |
| 19 | Gas | -40 to +80 | T5 |
| | Dust | -40 to +80 | T104°C |

17.5 Line fault detection shall not be fitted to equipment marked with a T6 temperature class.

17.6 When the equipment incorporates a 4-20 mA Transmitter Module, the output from the 4-20mA Transmitter Module shall only be connected to a 10k potentiometer, that has a 0.5 mm separation distance through a



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2122X
Issue 10

solid insulator, also located within the Valve Position Indicator. When the 4-20 mA Transmitter Module is fitted, a maximum of two switches is permitted.

- 17.7 The manufacturer shall carry out a dielectric strength test on 100% of manufactured units in accordance with EN 60079-11:2012 as follows: apply a voltage of 500 Vrms to all input terminals and the outer enclosure for a minimum of 60 s. Alternatively, apply a test voltage of 600 Vrms for 1 sec; or a test voltage of 707 Vdc for 60 sec; or a test voltage of 845 Vdc for 1 sec. There shall be no evidence of flashover or breakdown and the maximum current flowing shall not exceed 5 mA.
- 17.8 The earthing facility of the Series 36 GO switch shall not be used.

Project Number 80188648

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands

Certificate Annexe



Certificate Number: Sira 14ATEX2122X
Equipment: TX* Series Valve Position Indicators
Applicant: TopWorx Inc.

Issue 0

| Drawing No. | Sheets | Rev | Date (Sira stamp) | Title |
|-----------------|--------|-----|-------------------|---------------------------|
| CERT-ES-01846-1 | 1 of 1 | 18 | 31 Jul 14 | Marking, TX-series, ATEX |
| CERT-ES-03606-1 | 1 of 1 | 13 | 31 Jul 14 | GA, TX-series, IECEx/ATEX |

Issue 1

| Drawing no. | Sheets | Rev. | Date (Sira stamp) | Title |
|-----------------|--------|------|-------------------|--|
| CERT-ES-03606-1 | 1 of 1 | 14 | 25 Aug 15 | GA, TX-series, IECEx/ATEX |
| CERT-PS-00675-1 | 1 to 3 | 3 | 10 Sep 15 | Assembly, Board Go Numar Simulator (schematic pcb, layout board, parts list. |
| CERT-ES-02175-1 | 1 of 1 | 4 | 10 Sep 15 | Assy, Sub switch 35 |
| CERT-ES-01846-1 | 1 of 1 | 19 | 23 Sep 15 | Marking, TX-series, ATEX |

Issue 2

| Drawing | Sheets | Rev. | Date(Sira stamp) | Title |
|-----------------|--------|------|------------------|--------------------------|
| CERT-ES-01846-1 | 1 of 1 | 20 | 30 Sep 16 | Marking, TX-series, ATEX |
| CERT-ES-03606-1 | 1 of 1 | 16 | 01 Sep 16 | TXP/S Master assembly |

Issue 3

| Drawing | Sheets | Rev. | Date (Sira stamp) | Title |
|-----------------|--------|------|-------------------|------------------------|
| CERT-ES-01846-1 | 1 of 1 | 22 | 11 Feb 19 | Nameplate |
| CERT-ES-02343-1 | 1 of 1 | 17 | 17 Jan 19 | Nameplate Schedule Dwg |

Issue 4

| Drawing | Sheets | Rev. | Date (Sira stamp) | Title |
|-----------------|--------|------|-------------------|---|
| CERT-ES-02343-1 | 1 of 1 | 18 | 15 Feb 19 | Nameplate |
| ES-06719-1 | 1 to 4 | 1 | 15 Feb 19 | Sensor Assembly MINI-GO |
| ES-06720-1 | 1 to 2 | 2 | 15 Feb 19 | Switch Assembly Mini GO & Euro-Connector Assembly |
| ES-06753-1 | 1 of 1 | 1 | 15 Feb 19 | Wiring Diagram DS & SS |
| ES-06752-1 | 1 of 1 | 1 | 15 Feb 19 | Wiring Diagram D2, D4 |

Issues 5 and 6 - No new drawings were introduced.

Issue 7

| Drawing | Sheets | Rev. | Date (Stamp) | Title |
|-----------------|--------|------|--------------|-----------------|
| CERT-ES-08677-1 | 1 to 7 | AA | 29 Jul 20 | Internal labels |

Issue 8 - No new drawings were introduced.

Issue 9

| Drawing | Sheets | Rev. | Date (Stamp) | Title |
|-----------------|--------|------|--------------|-------------------------|
| CERT-ES-02205-1 | 1 of 1 | AA | 19 Dec 23 | Assembly, Potentiometer |

Issue 10 - No new drawings were introduced.

Project Number 80188648

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands